

Certificate of constancy of performance,

0832-CPR-F1140

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

CF3000 Intelligent Analogue Addressable 1-4 Loop Control and Indicating Equipment

(For full product details and conditions of use refer to appendix)

Produced by or for

Eaton Electrical Systems Limited

**Wheatley Hall Road
Doncaster
South Yorkshire
DN2 4NB
United Kingdom**

and produced in the manufacturing plant(s)

Eaton Electrical Products Limited

**Llantarnam Park
Cwmbran
Gwent
NP44 3AW
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 54-2:1997 + A1:2006 - Control and indicating equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment**

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 18 July 2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



E Mattie-Suleiman, Technical Development Director
On behalf of BRE Global Limited
Date of issue: 25 November 2016
Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F1140

Incorporating the following units:

ADF6 Back	Assembled back box
YPCB2153	Motherboard PCB
YPCB2147	PSU PCB
YPCB2148	2 Loop Card (2 off)
ADF6Screen	Touch Screen
YPCB2185	Complete Display + Micro PCB
ADF6 DISPCOVER	Display PCB Cover
ADF6FACIA	Front Moulding
ADF6PRINTDOOR	Printer Door Moulding
BAT-NP12-12	Batteries (2 off)
ADF6HINGE	Door Hinges

Incorporating the following optional modules:

ADF6OPFACIA	Optional Anti Tamper Cover
ADF6PRINTER	Printer
YPCB2187	Fire Brigade Interface
YPCB2137	Micro Display card
YPCB2319	Sounder loop card
YPCB2433	FRE/FPE loop card
YPCB2222	Loop splitter card
YPCB2145LED	LED board
YPCB2202	Single channel Network card
YPCBNCDRUL	Dual channel Network card

Certified with the following options with requirements from EN 54-2:

7.8	Output to fire alarm device(s)
7.9.1	Output to fire alarm routing equipment
7.10.1	Output to automatic fire protection equipment (Type A)
7.10.2	Output to automatic fire protection equipment (Type B)
7.11	Delays to outputs
7.12.3	Dependencies on more than one alarm signal (Type C)
7.13	Alarm counter
8.9	Output to fault warning routing equipment
9.5	Disabling of each address point
10	Test condition

Notes:

1. The scope of approval does not include the network functionality.
2. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.



E Mattie-Suleiman, Technical Development Director
On behalf of BRE Global Limited
Date of issue: 25 November 2016
Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.